

Date Here  
Your Name Here

INSPECTION OF THE HOUSE AT Address Here

I inspected the new floor slab location and waste line in the above house for compliance with the UBC.

The floor slab is aprox 25x25 and reinforced with number 4 reinf bars at 4 feet on center and properly doweled into the existing slab and foundations. The slab conforms to the UBC.

The waste line is a 2" black abs line with proper fall and trap at the floor drain. The floor drain is properly vented with a separate abs line up through a nearby wall and out through the roof. The waste line conforms to the UBC.

Thank You

William S. Culbertson  
Architect  
Colorado Number 302548